



# South Montgomery County Fire Department



27900 Robinson Road • Conroe, Texas 77385 • P (281) 363-3473 • F (281) 292-0487  
www.mcesd8.org - inspections@mcesd8.org

## Required Inspections for South Montgomery County Fire Department

### Inspections Before Your Final

Underground Piping Cover Up;
Underground Piping System Hydro Inspection;
Aboveground Piping System Hydro Inspection (20+ heads for new systems) (51+ for existing systems);
Above Ceiling Pipe Cover-Up Inspection;
Above Ceiling Cover-Up Inspection HVAC, Plumbing and Electrical;
Alarm System Cabling Supports and Hangers Inspection;
Rated Wall Assemblies;
Rated Shaft Walls

All alarm and sprinkler submittals **MUST BE** approved before any ceiling inspections can take place.

**Please email [inspections@mcesd8.org](mailto:inspections@mcesd8.org) to request any inspections.** Please provide the Name of Project, Address of Project, and Contact Name and Number.

### Final Inspection

Access Control
Elevator Inspection Phase I and II-Must Have State Inspection Prior to SMCDFD Inspection;
Kitchen Inspection-Vent Hood Suppression System, Gas or Electrical Shut Off;
Electronic Lock Inspection;
Generator Back Up Power Systems;
Parking Lot Inspection Including Fire Lanes and Fire Department Access;
Sprinkler System Acceptance Test;
Fire Sprinkler Pump and Tank Inspection;
Standpipe Connections;
Fire Alarm System Functional Test;
Mechanical HVAC Shut Down;
Final Inspection Walk With General Contractor For Building COC Inspection

A final inspection must be requested by submitting the Request for Final Inspection form. You can find that form located on the Montgomery County Fire Marshal's website [www.mctx.org/fire](http://www.mctx.org/fire). This is for Fire Code permitted projects only.

Your Certificate of Compliance will be issued from the Montgomery County Fire Marshal's office and will be emailed within 72 business hours.