



South Montgomery County Fire Department



27900 Robinson Rd · Conroe, TX 77385 · P. (281) 363-3473 · F. (281) 292-0487
www.mcesd8.org

Inspections

Prior to requesting a final inspection, you must submit any fire protection checklists to our office. These checklists are found on our website. <http://mcesd8.org/page/fireinspectionforms>. Checklists are on the Permits page under the Inspections tab.

Underground

- Permit/ Plans Review
- Pipe size/ proper install, Vault (once installed)
- Hydro (should Be done while pipe is exposed)/ Flush

Above Ground Sprinkler

- Permit/ Plans Review
- Pipe size visual (before any cover-up)
- Hydro
- Final

Fire Alarm

- Permit/ Plans Review
- Fire Pump

Final

- Permit/ plans Review
- Initial start-up
- Flow/ Certification tests/ Final

Fixed Chemical

- Permit/ Plans Review
- Final (check operation)

Special Inspections

- Fire proof/ Shaft Inspections
- Fuel tank removal and Install